



BRIHANMUMBAI MUNICIPAL CORPORATION
MUMBAI FIRE BRIGADE
FIRE SAFETY COMPLIANCE CERTIFICATE
(EXISTING HEALTH LICENSE)



Ward: K/East

Health License No. 761409449

Application No.:1600021016

This compliance Certificate is issued with respect to fire safety point of view only & does not guarantee for the issuance of Trade License. Compliance of the fire safety measures is for minimizing the chance of occurrence of fire through active and passive measures. Any noncompliance at any instance may cause occurrence of fire.

Name of Establishment : M/S RASHMI FOODS PVT. LTD.
Address of Establishment : UNIT NO. 41, X UPPER GROUND FLOOR,
MISTRI INDUSTRIAL ESTATE, MIDC CROSS
ROAD, ANDHERI (E), MUMBAI-400069.
Name of Licensee Trade : MR. SACHIN DESHPANDE.
Trade : PREPARATION & SELL EATABLE

This is the compliance with respect to the Earlier Issued Fire safety requirements Letter for the use of PNG as a fuel of above mentioned trade and issued as per the undertaking cum indemnity bond submitted by the applicant. During the inspection, it was noticed that the online codified Fire safety requirements are complied with. However, if any non-compliance of Fire safety requirements is noticed in the premises after the inspection, then the inspecting officer / approving officer or this department will not be responsible for the same.

However it is the duty / responsibility of Owner / Occupier of the premises to maintain the fire prevention & life safety measures in good repair & efficient condition all the time in accordance with the provisions in Section 3 (1) of Maharashtra Fire Prevention & Life Safety Measures Act. If applicable the certificate in prescribed form (Form – B) from a Licensed Agency shall be submitted twice a year in the months of January & July, regarding the maintenance of Fire safety & life safety measures in accordance with the provisions in Section 3 (3), to the Nominated Officer / Chief Fire Officer.

REMARKS:

- 1) This Fire Safety Compliance certificate is issued for the compliance of Earlier Issued Fire safety requirements Letter FB/L/R-VI/Stn.No.20/294 Dated 26/03/2016 for the trade of Preparation & Sell Eatable by using PNG as a fuel, with 06 No's of Burners, 02 No's of Tandoor Bhatti & 03 No's of Electric Appliances in kitchen of above said admeasuring an area of about 52.04 sq. meters. housed on Ground floor of above said Premises.
- 2) The party has uploaded following documents: -
 - I. Form A from M/S. FSI CORPORATION Govt. approved License. Agency (Lic. No: MFS-LA/RF-108/RD-105/RP-29) for the Installation of Fire Retardant Door & Fire Extinguishers.
 - II. Form A from M/S. TARGET SAFETY PRODUCTS & SERVICES Govt. approved License. Agency (Lic. No: MFS-LA/RF-280/RD-257/RP-052) for the Installation of Gas Leak Detector.
 - III. Electric Audit from M/S. ASHOK ELECTRC CO. having permit no. B.C.-1160

The party has paid scrutiny fees of Rs. 11,000.00/- vide Receipt No. 712534264 dated 09.12.2022 on total area of premises of about 52.04 sq. meters.

**AJAY
JOTIRAM
JADHAV**

Digitally signed by AJAY JOTIRAM
JADHAV
DN: c=IN, o=Personal, title=7399,
pseudoym=8b9147d9c4331ee184d
405684db0112d1a45df4d8b914ccc
bba214c2180,
2.5.4.20=8436420188e44348405e584c
81fc7269d8fd3ac934cdd0d1253da7
e5bfb8de, postalCode=400102,
sn=Jadhav Ajay,
serialNumber=623400ab0d22b51fb82
d4b3b0f93aad2a0494c4bbd3b055
65a01b4540190, cn=AJAY JOTIRAM
JADHAV
Date: 2022.12.10 18:02:52 +05'30'

**Inspecting Officer
Mumbai Fire Brigade**

**SURENDRA
KRISHNA
SAWANT**

Digitally signed by
SURENDRA KRISHNA
SAWANT
Date: 2022.12.11 20:45:31
+05'30'

**Approving Officer
Mumbai Fire Brigade**

Note:

- 1) The verification of Authenticity of structure, Mezzanine floor, Loft, Addition, Alteration, Change of user, Amalgamation, authorized/ Unauthorized construction, Encroachment, Area of the premises is not under the purview of this department and will not be responsible for any illegality and its consequences thereof.
- 2) In case adverse remarks received from A.E. (B &F), K/E Ward then this compliance certificate is treated as cancelled.